



ADDENDUM NO. 2

From: Municipality of West Grey

Date: Thursday, September 10, 2020

Addendum No. 2
Municipality of West Grey
Project No.: 5302-20
Tender – Rehabilitation of Structure 17

Closing Date: Friday, September 11, 2020 at 2:00:59 p.m.

Please be advised of following clarifications to this project as attached.

I/We hereby acknowledge receipt of this Addendum.

Signed (Must be Signing Officer of Firm)

Name (Print) Date:

Position

Name of Firm

Please update your Tender documents as per the addendums in this document and attach a copy of this addendum page to your submission acknowledging receipt and understanding of the addendum.

MUNICIPALITY OF WEST GREY
PROJECT No. 5302-20
TENDER – Rehabilitation of Structure 17

ADDENDUM NO. 2
Date: Thursday, September 10, 2020

Please be advised of the following:

The Municipality of West Grey reserves the right to reject any or all tenders and the lowest price will not necessarily be accepted.

CLARIFICATION QUESTION

Question No. 1:

Is MicroProSienna wood treatment acceptable?

Answer No. 1:

Note 5 on Drawing No. 01 - Preservation treatment such as Micronized Copper Azole (MCA) may be considered as an alternative. Bidders shall indicate with their submission, the Contractor's choice of preservation treatment on attached revised page 3 (to be used in tender submission)

End of Addendum No. 2

SCHEDULE OF UNIT PRICES

CONTRACT NO.: 5302-20

In the column headed "Spec. No.", the number refers to the latest issue of the Ontario Provincial Standard Specification. Where the number is preceded by "M", the number refers to the latest issue of the Ontario Provincial Standards for Roads and Public Works – Volume 7 – Municipal Oriented. "S.P." refers to the Special Provision.

ITEM NO.	SPEC NO.	DESCRIPTION	EST. QTY.	UNIT	UNIT PRICE	TOTAL PRICE
STRUCTURE 17						
1.01	S.P.	Mobilization and Demobilization	100%	L.S.		
1.02	S.P.	Remove and Dispose of Existing Timber Decking	100%	L.S.		
1.03	S.P.	Clean and Coat the Top Flange of the Floor Beams and Stringers (Provisional)	100%	L.S.		
1.04	S.P.	Access to Work Areas, Platforms and Scaffolding	100%	L.S.		
1.05	907 S.P.	Supply and Install New Nail Laminated Timber Deck (NLT)	100%	L.S.		
1.06	907 S.P.	Supply and Install New Timber Wearing Boards	100%	L.S.		
1.07		Provide Bonding	100%	L.S.		
SUB-TOTAL – STRUCTURE 17						\$ _____
CONTINGENCY ALLOWANCE						\$ 20,000.00
TOTAL PRICE (Excluding H.S.T.)						\$ _____

Contractor's Choice of Preservation Treatment: _____